

Columbia Gas Plumber's Guide Revision 1/2008

Major Changes

(See PG Preface for more details.)

Part 1 – General

- 1.3.2 (c) & 1.6 revised to remove MJ Card.
- 1.6 Definitions added for High Density Plastic and Medium Density Plastic, and High Pressure Regulator were redefined.

Part 2 – Customer Service Lines

- 2.3.4 Additional information was added for the “Fusion Qualification Card” requirement.
- 2.4.2(d) Added HP service sizing information and referenced new sizing Table 4 in Appendix C.
- 2.5.1(h) Maximum plastic pipe age reduced to 24 months. Revised who can test.
- 2.5.5 Tracer wire material specification removed and referenced in the Materials for Customer Service Lines manual.
- 2.6.3(h) Added to require tracer wire connection to steel casing, reinforcing Note @ 2.5.5.

Part 3 – Meter Settings

- 3.1.7 EXCEPTION: Added for testing to re-establish service as required by PUCO Service Standards.
- 3.3.7 Re-titled to also cover Grounding and Bonding with Electrical Isolation, and Bonding connection information was added in (c).

Part 4 – Inspection and Testing

- 4.1.5 Leak Detection was expanded to permit additional methods (was 4.1.6).
- 4.2.4 Meter Installation state-specific criteria added.
- 4.3 Testing Requirements were substantially re-written to cover policy change and state specific requirements.

Appendix A – Explanatory Information

- A.4.3(b) Exceptions 1 & 2 were re-written to cover policy change and state specific requirements.

Appendix E – Forms

- Form 2 – Removed C-2300 “Mechanical Joint Card” with completion instructions.