



THE STANDARD DRAWING DEPICTED HERE HAS BEEN DESIGNED IN ACCORDANCE WITH USDOT PIPELINE SAFETY STANDARDS SET FORTH AT 49 CFR PART 192, AND THE REQUIREMENTS OF NFPA 54. DEVIATION FROM THIS DRAWING, EITHER IN MATERIALS OR SPECIFICATIONS, WITHOUT THE WRITTEN APPROVAL OF THE NISOURCE INC. DESIGN ENGINEER IS NOT AUTHORIZED, AND NISOURCE, INC. WILL NOT BE HELD ACCOUNTABLE FOR THE IMPROPER OPERATION OF THE FACILITY. A QUALIFIED PLUMBER, OTHER INSTALLER OR THE MANUFACTURER SHOULD BE CONSULTED FOR PROPER INSTALLATION AND/OR TESTING OF THIS FACILITY, AND NEITHER NISOURCE, INC. NOR ANY AFFILIATE OR SUBSIDIARY OF NISOURCE, INC. SHALL BE RESPONSIBLE FOR THE INSTALLATION AND/OR TESTING OF THE FACILITY.

Note:

IN KENTUCKY, THE COMPANY WILL INSTALL THE RISER

NiSource™

**NiSource Energy
Distribution**

DRAWING TITLE

DOMESTIC OUTSIDE
METER SETTING

DRAWN
CR EMERSON

DATE
03-03-03

DRAWING NO.
PLMB-0001

ISSUE NO.

CHECKED

DATE

SHEET NO.
1 of 2



BILL OF MATERIAL

ITEM	QTY.	SIZE	DESCRIPTION
1	1	1"/20 LT	METER, DOMESTIC, PROVIDED BY COLUMBIA GAS
2	1	SEE NOTE 7	RISER, APPROVED ANODELESS, PRE-BENT STEEL ENCASED OR FLEX CASING
3	1	SEE NOTE 7	RISER BRACKET, FOR ATTACHMENT TO MASONARY WALL

NOTES

1. REFER TO COLUMBIA GAS STANDARDS FOR CUSTOMER SERVICE LINES, METERS, AND SERVICE REGULATORS (PLUMBER'S GUIDE) FOR PROPER METER SET INSTALLATION INSTRUCTIONS.
2. APPROVED METER SUPPORT MUST BE USED.
3. IF THE SERVICE LINE IS STEEL, CONTACT COLUMBIA GAS PERSONNEL FOR SPECIFIC INSTALLATION INSTRUCTIONS.
4. PREFABRICATED RISERS AND BRACKETS MUST BE INSTALLED AND SECURED ACCORDING TO THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
5. THE METER MUST BE INSTALLED IN A LEVEL POSITION.
6. NO SCREW FITTINGS ARE TO BE USED BELOW GROUND.
7. THESE ITEMS MUST BE APPROPRIATELY SIZED FOR THE SPECIFIC CONDITIONS.
8. WHEN MEASURING FROM A LOW PRESSURE SYSTEM, USE A LOW PRESSURE PREFAB METER BAR ASSEMBLY (WITHOUT A REGULATOR).

DRAWN CR EMERSON	DATE 03-03-03	DRAWING NO. PLMB-0001	ISSUE NO.
CHECKED	DATE	SHEET NO. 2 OF 2	